


| | | |
|--|---|--------------------------------|
|  | National declaration of performance | Number: 142/KAN-DWU/22E |
| | System KAN-therm ultraPRESS PERTAL pipes in insulation | Page 1 z 2 |

1. Name and trade name of building product:

System KAN-therm ultraPRESS PERTAL pipes in insulation [Ø16-32 mm]

2. Designation type of building product:

System KAN-therm ultraPRESS PERTAL 5L PE/RT II/Al/PE-RT II pipes in insulation

3. Intended use or uses:

For use in indoor installations of cold and hot utility water, drinking water, central radiator heating in accordance with the "Designer's and contractor's guide" issued by KAN Sp. z o.o., the catalog of the KAN-therm System and the guidelines of the KAN Technical Department.

4. Name and address of the producer and place of manufacture:

KAN Sp. z o.o.
Zdrojowa 51 PL-16-001 Białystok-Kleosin
Poland
www.kan-therm.com e-mail: kan@kan-therm.com

5. Name and address of the authorized representative, if appointed: Not applicable

6. National system used for assessment and verification of performance constancy:

System 3 and 4

7. National technical specification:

7a. Polish product standard:

PN-EN ISO 21003-2:2009/A1:2011- Multilayer piping systems for hot and cold water installations inside buildings - Part 2: Pipes.


PN-EN 14313:2016-04 – Thermal insulation products for building equipment and industrial installations - Factory made polyethylene foam (PEF) products – Specification.

Name of the accredited laboratory and accreditation number:

KIWA Nederland B.V., Accreditation Council RvA, accreditation no.: L015

7b. National technical assessment:

Not applicable.

| | | |
|--|---|--------------------------------|
|  | National declaration of performance | Number: 142/KAN-DWU/22E |
| | System KAN-therm ultraPRESS PERTAL pipes in insulation | Page 2 z 2 |

8. Declared performance:

| Essential characteristics of the construction product for the intended use or uses | Declared performance | Remarks |
|--|---|---|
| Geometric features | Accordance to KAN specifications and PN-EN ISO 21003-2:2009 Insulation thickness 6 mm | |
| Pipe structure | Type M acc. PN-EN ISO 21003-2:2009 | |
| Mechanical properties | Design internal pressure resistance determined in accordance with PN-EN ISO 21003-2:2009 Class 1-5/10 bar | |
| Physical properties | Thermal stability acc. to PN-EN ISO 21003-2:2009, p. 10.2 class 1 – $T_{rob}=60\text{ °C} / T_{max}=80\text{ °C}$ class 2 – $T_{rob}=70\text{ °C} / T_{max}=80\text{ °C}$ class 4 – $T_{rob}=60\text{ °C} / T_{max}=70\text{ °C}$ class 5 – $T_{rob}=80\text{ °C} / T_{max}=90\text{ °C}$ Thermal conductivity of the insulation λ at avg. 40 °C - 0.036W / mK Insulation absorption: method B - 1% | |
| Marking | Accordance to: PN-EN ISO 21003-2:2009 | |
| Reaction to fire | Class E | |
| Impact on drinking water | Approved for contact with drinking water | Hygienic certificate PZH B.BK.60110.0862.2022 PCA accreditation Nr AB 509 |

9. The performance of the product described above is in accordance with all of the declared performance characteristics mentioned in point 8. This national declaration of performance is issued in accordance with the Act of 16 April 2004 regarding construction products, under the sole responsibility of the manufacturer.

On behalf of manufacturer signed by:

Manager of the Quality Assurance Department



Kleosin – 03.10.2022
(place – date of issue)

Janusz Żukowski
(signature)